



TABLOUL ELECTRIC GENERAL PARC		TE.G						
Caracteristici principale	u.m.	DETALIERE :	DESCARCATOR Tip 2	CP.01	C.01	C.02	CF.01	REZERVA Spatiu 20%
Circuit	[-]	Tablou Electric	SPD	3 x Prize Schuko	Circuit iluminat stalpi iluminat	Circuit iluminat stalpi iluminat	Irigatii	1,0
Putere electrica instalata	kW	6,00		2,0	1,0	1,0	1,0	1,0
Putere electrica absorbita	kW	5,10		1,4	1,0	1,0	1,0	1,0
Faza incarcata	[-]	L1,L2,L3, N, PE		L, N, PE	L, N, PE	L, N, PE	L, N, PE	
Tip cablu	[-]	CYAbY		CYY-F	CYAbY	CYAbY	CYAbY	
Sectiune cablu	mm²	3 x 25		3 x 2,5	3 x 6	3 x 6	3 x 2,5	
Tub de protectie	[-]	-						-
Diametru tub protectie / canal cablu	mm							-
Curentul de calcul I	A	8,18		6,76	4,83	4,83	4,83	
Coeficient de utilizare Ku	0,85							
Cos φ	0,9							

LEGENDA

- C.01 - Circuite iluminat
- LL- locuri de lampa,
- IAD - intreruptor automat prevazut cu protectie diferentiala,
- IA - intreruptor automat,
- CYY-F - Cablu cu intarziere la propagarea flacarii in manunchi, cu emisii reduse de fum
- CYAbY-F - Cablu cu intarziere la propagarea flacarii in manunchi, cu emisii reduse de fum, cu manta metalica
- L - conductor de faza,
- N - conductor de nul,
- K - Contactor
- BEP - Bara de egalizare a potentialelor



pr. general:
sc SPORT PLAY SYSTEMS srl

Adresa:
str. Colea Victoriei, nr. 7/19,
Turda, jud. Cluj,
Romania
0040 742 774 046
office@sportplay.ro

pr. specialitate:
sc JONEQ DESIGN&CONSULT srl

Adresa :
str. Alba Iulia nr.28 , Bistrita
0040 742 406 476
joneq.dc@gmail.com

nr. pr.:
20 | 2023

data:
11.2023

beneficiar:
Municipiul Targu Mures

adresa:
str. Parcul Sportiv Municipal, nr. 4, mun.
Targu Mures, jud. Mures

titlu proiect:
Amenajare Skatepark in Parcul Sportiv Municipal, mun. Targu Mures, jud. Mures
str. Parcul Sportiv Municipal, nr. 4, mun.
Targu Mures, jud. Mures

titlu plansa:
Schema monofilara instalatii electrice

scara:
1:500

faza:
C.U.

nr. plansa:

IE.02